

BACnet Protocol Implementation Conformance Statement (Annex A)

Date: February 24, 2016

Vendor Name: ADFweb.com S.r.l.

Product Name: BACnet slave / KNX - Converter

Product Model Number: HD67802-KNX-BIP-B2, HD67802-KNX-BMSTP-B2

Application Software Version: 1.0 **Firmware Revision:** 1.0 **BACnet Protocol Revision:** 12

Product Description:

Converter between BACnet and KNX.

BACnet Standardized Device Profile (Annex L):

- | | |
|---|--|
| <input type="checkbox"/> BACnet Operator Workstation (B-OWS) | <input type="checkbox"/> BACnet Advanced Application Controller (B-AAC) |
| <input type="checkbox"/> BACnet Advanced Operator Workstation (B-AWS) | <input checked="" type="checkbox"/> BACnet Application Specific Controller (B-ASC) |
| <input type="checkbox"/> BACnet Operator Display (B-OD) | <input type="checkbox"/> BACnet Smart Sensor (B-SS) |
| <input type="checkbox"/> BACnet Building Controller (B-BC) | <input type="checkbox"/> BACnet Smart Actuator (B-SA) |

List all BACnet Interoperability Building Blocks Supported (Annex K):

DS-RP-B Data Sharing – ReadProperty – B

DS-WP-B Data Sharing – WriteProperty –B

Segmentation Capability:

- | | |
|--|-------------------|
| <input type="checkbox"/> Able to transmit segmented messages | Window Size _____ |
| <input type="checkbox"/> Able to receive segmented messages | Window Size _____ |

Standard Object Types Supported:

| Object Type Supported | Can be created dynamically | Can be deleted dynamically |
|------------------------|----------------------------|----------------------------|
| Analog Input | No | No |
| Analog Output | No | No |
| Analog Value | No | No |
| Binary Input | No | No |
| Binary Output | No | No |
| Binary Value | No | No |
| Positive Integer Value | No | No |
| Large Analog Value | No | No |
| Integer Value | No | No |
| Multi-State Input | No | No |
| Multi-State Output | No | No |
| Multi-State Value | No | No |
| Life Safety Point | No | No |
| Life Safety Zone | No | No |
| Access Door | No | No |
| Accumulator | No | No |
| Device | No | No |

No optional properties are supported. No proprietary properties are present.

Analog Input Properties

| | | |
|-------------------|---------------|----------------|
| Object_Identifier | Present_Value | Event_State |
| Object_Name | Description | Out_Of_Service |
| Object_Type | Status_Flags | Units |

Analog Output Properties

| | | |
|-------------------|---------------|----------------|
| Object_Identifier | Present_Value | Event_State |
| Object_Name | Description | Out_Of_Service |
| Object_Type | Status_Flags | Units |

Analog Value Properties

| | | |
|-------------------|---------------|----------------|
| Object_Identifier | Present_Value | Event_State |
| Object_Name | Description | Out_Of_Service |
| Object_Type | Status_Flags | Units |

Binary Input Properties

| | | |
|-------------------|---------------|----------------|
| Object_Identifier | Present_Value | Event_State |
| Object_Name | Description | Out_Of_Service |
| Object_Type | Status_Flags | Polarity |

Binary Output Properties

| | | |
|-------------------|---------------|----------------|
| Object_Identifier | Present_Value | Event_State |
| Object_Name | Description | Out_Of_Service |
| Object_Type | Status_Flags | Polarity |

Binary Value Properties

| | | |
|-------------------|---------------|----------------|
| Object_Identifier | Present_Value | Event_State |
| Object_Name | Description | Out_Of_Service |
| Object_Type | Status_Flags | Polarity |

Positive Integer Value Properties

| | | |
|-------------------|---------------|----------------|
| Object_Identifier | Present_Value | Event_State |
| Object_Name | Description | Out_Of_Service |
| Object_Type | Status_Flags | Units |

Large Analog Value Properties

| | | |
|-------------------|---------------|----------------|
| Object_Identifier | Present_Value | Event_State |
| Object_Name | Description | Out_Of_Service |
| Object_Type | Status_Flags | Units |

Integer Value Properties

| | | |
|-------------------|---------------|----------------|
| Object_Identifier | Present_Value | Event_State |
| Object_Name | Description | Out_Of_Service |
| Object_Type | Status_Flags | Units |

Multi-State Input Properties

| | | |
|-------------------|---------------|------------------|
| Object_Identifier | Present_Value | Event_State |
| Object_Name | Description | Out_Of_Service |
| Object_Type | Status_Flags | Number of States |

Multi-State Output Properties

| | | |
|-------------------|---------------|------------------|
| Object_Identifier | Present_Value | Event_State |
| Object_Name | Description | Out_Of_Service |
| Object_Type | Status_Flags | Number of States |

Multi-State Value Properties

| | | |
|-------------------|---------------|------------------|
| Object_Identifier | Present_Value | Event_State |
| Object_Name | Description | Out_Of_Service |
| Object_Type | Status_Flags | Number of States |

Life Safety Point Properties

| | | |
|-------------------|--------------------|----------------|
| Object_Identifier | Present_Value | Event_State |
| Object_Name | Description | Out_Of_Service |
| Object_Type | Status_Flags | Tracking_Value |
| Reliability | Mode | Accepted_Modes |
| Silenced | Operation_Expected | |

Life Safety Zone Properties

| | | |
|-------------------|--------------------|----------------|
| Object_Identifier | Present_Value | Event_State |
| Object_Name | Description | Out_Of_Service |
| Object_Type | Status_Flags | Tracking_Value |
| Reliability | Mode | Accepted_Modes |
| Silenced | Operation_Expected | |

Access Door Properties

| | | |
|-------------------------|-----------------|--------------------------|
| Object_Identifier | Present_Value | Event_State |
| Object_Name | Description | Out_Of_Service |
| Object_Type | Status_Flags | Relinquish Default |
| Reliability | Door Pulse Time | Door Extended Pulse Time |
| Door Open Too Long Time | | |

Accumulator Properties

| | | |
|-------------------|----------------|----------------|
| Object_Identifier | Present_Value | Event_State |
| Object_Name | Description | Out_Of_Service |
| Object_Type | Status_Flags | Scale |
| Units | Max_Pres_Value | |

Device Properties

| | | |
|-------------------|-------------------------------|---------------------------------|
| Object_Identifier | Model_Name | Protocol_Object_Types_Supported |
| Object_Name | Firmware_Revision | Object_List |
| Object_Type | Application_Software_Revision | Max_APDU_Length_Accepted |
| System_Status | Protocol_Version | Segmentation_Supported |
| Vendor_Name | Protocol_Revision | |
| Vendor_Identifier | Protocol_Services_Supported | |

Data Link Layer Options:

- ☒ BACnet IP, (Annex J)
- ☐ BACnet IP, (Annex J), Foreign Device
- ☐ ISO 8802-3, Ethernet (Clause 7)
- ☐ ATA 878.1, 2.5 Mb. ARCNET (Clause 8)
- ☐ ATA 878.1, EIA-485 ARCNET (Clause 8), baud rate(s)
- ☐ MS/TP master (Clause 9), baud rate(s):
- ☒ MS/TP slave (Clause 9), baud rate(s): 9600, 19200, 38400, 57600, 76800, 115200
- ☐ Point-To-Point, EIA 232 (Clause 10), baud rate(s):
- ☐ Point-To-Point, modem, (Clause 10), baud rate(s):.
- ☐ LonTalk, (Clause 11), medium:
- ☐ BACnet/ZigBee (ANNEX O)
- ☐ Other:

Device Address Binding:

Is static device binding supported? (This is currently necessary for two-way communication with MS/TP slaves and certain other devices.) ☐ Yes ☒ No

Networking Options:

- ☐ Router, Clause 6 - List all routing configurations, e.g., ARCNET-Ethernet, Ethernet-MS/TP, etc.
- ☐ Annex H, BACnet Tunneling Router over IP
- ☐ BACnet/IP Broadcast Management Device (BBMD)
 - Does the BBMD support registrations by Foreign Devices? ☐ Yes ☐ No
 - Does the BBMD support network address translation? ☐ Yes ☐ No

Character Sets Supported:

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.

- | | | |
|---|---|-------------------------------------|
| <input checked="" type="checkbox"/> ISO 10646 (UTF-8) | <input type="checkbox"/> IBM™/Microsoft™ DBCS | <input type="checkbox"/> ISO 8859-1 |
| <input type="checkbox"/> ISO 10646 (UCS-2) | <input type="checkbox"/> ISO 10646 (UCS-4) | <input type="checkbox"/> JIS X 0208 |

If this product is a communication gateway, describe the types of non-BACnet equipment/networks(s) that the gateway supports:

KNX network

Network Security Options:

- ☒ Non-secure Device - is capable of operating without BACnet Network Security
- ☐ Secure Device - is capable of using BACnet Network Security (NS-SD BIBB)
 - ☐ Multiple Application-Specific Keys:
 - ☐ Supports encryption (NS-ED BIBB)
 - ☐ Key Server (NS-KS BIBB)